UNIT #06238


12' X 25' RESTROOM BUILDING



This drawing is the property of Pacific Mobile Structures, Inc. and may not be duplicated without approval. Actual features may vary due to available inventory.









PANEL SCHEDULE									PANEL No.		MDP	
LANET SCHEDOL						ுட்				LOCATION:		
MOUNTING: FLUSH				120/240 VOL			VOL.	rs	1 PHASE		WIRE:	4
ENC	NEMA 3R		100			AMPS	W	/ MAIN	BREAKER	10,000	AIC	
CK	DESCRIPTION	KVA	Р	AMP	Α	В	AMP	Р	KVA	DESCRIPTIO	N	СК
1	HEAT PUMP	3.3	2	40	·	Г	30	1	1.5	WATER HEATER		2
3		3.3				٠	20	1	1.5	HEAT TRACE		4
5	LIGHTS/FANS	0.6	1	20	ŀ		20	1	0.7	GEN RECEPT		6
7	SIGN LIGHT	1.2	1	20	L	٠						8
9					ŀ							10
11						٠						12
13					ŀ							14
15						٠						16
17					•							18
CONTRIBUTION FROM PANEL					TOTAL CONNECTED						12.1	_
	6.1						KVA AMPS	50.5				
l	PHASE B:	6.0										
ı	12.1	TOTAL DEMAND KVA							12.7			
										AMPS:	52.9	



Shown w/optional skirting

LEGEND Panel Box

Porch Light

Thermostat

□ Duplex Outlet \$Light Switch | Empty data box Perm. Interior wall □ Temp. Interior

FEATURES

- Outrigger Chassis w/hitch
- Sheet vinyl flooring
- FRP interior wall covering
- Fixed Ceiling
- 4' fluorescent strip light
- Endwall HVAC w/ducted supply 100% fresh air

- **Duro-Last membrane roofing**
- LP SmartPanel siding Grey siding / Blue trim
- Tank type toilets, flush valve urinals
- 3068 Painted steel exterior doors w/ closer, passage, and deadbolt